PARTNER | SOLVE | DELIVER®

LEAKAGE INDUCTANCE INTO TRANSFORMER WINDINGS

Proper Integration

Standex Electronics

LEAKAGE INDUCTANCE IN WINDINGS

Proper Integration



Proper Integration of Leakage Inductance into Transformer Windings

Integrating leakage inductance into transformer windings is an important consideration for accurate modeling and analysis of transformer behavior. Leakage inductance refers to the magnetic field produced by a transformer that does not link both the primary and secondary windings. It is caused by the magnetic flux lines that do not couple the two windings tightly together.

To properly integrate leakage inductance into transformer windings, you can follow these steps:

1. Determine the leakage inductance value:

Leakage inductance is typically specified by the transformer manufacturer or can be measured experimentally. It represents the amount of magnetic flux that does not couple the windings. Leakage inductance is usually given as a value in henries (H) or millihenries (mH).

2. Design the transformer windings:

When designing the transformer windings, take into account the leakage inductance by considering the physical separation as well as interleave between the primary and secondary windings. Increase the separation or reduce interleave between the windings to increase the leakage inductance, or decrease the separation and improve interleave to reduce it. The winding geometry, such as the number of turns, conductor spacing, and layer arrangement, affects the leakage inductance as well.

3. Model the leakage inductance:

Once you have the leakage inductance value or an estimate, you can incorporate it into your transformer model. This can be done in simulation software or mathematical equations used for transformer analysis. The leakage inductance is represented as an additional inductance component in series with each winding. Add this component to the primary and secondary windings of the transformer model.

4. Consider the impact on transformer performance:

The presence of leakage inductance affects the transformer's behavior in various ways. It can cause voltage drops, voltage regulation issues, and increased losses. Analyze the impact of leakage inductance on your specific transformer design to ensure it meets the desired performance criteria.

5. Validate the model:

Once you have integrated the leakage inductance into your transformer model, validate it through simulations or experimental tests. Compare the results with the expected behavior of the transformer and verify that the model accurately represents the real-world performance.

6. Get expert advise.

It's worth noting that integrating leakage inductance into transformer windings is a complex task that requires expertise in transformer design and analysis. If you're working on a critical application or require precise calculations, it's advisable to consult a qualified electrical engineer or transformer specialist.

PARTNER | SOLVE | DELIVER®

Standex Electronics

Standex Electronics
Worldwide Headquarters
4150 Thunderbird Lane
Fairfield, OH 45014 USA
+1.866.STANDEX (782.6339)
info@standexelectronics.com

Agile Americas (NH)
+1.800.805.8991
info@agilemagco.com

Minntronix Americas (SD)
+1.605.884.0195
productsales@minntronix.com

Renco Americas (FL)
+1.800.645.5828
sales@rencousa.com

StandexMeder Europe (Germany)
+49.7733.9253.200
salesemea@standexelectronics.com

StandexMeder Asia (Shanghai)
+86.21.37606000
salesasia@standexelectronics.com

Standex Electronics India (Chennai)
+91.98867.57533
salesindia @standexelectronics.com

Standex Electronics Japan (Kofu)
+81.42.698.0026
sej-sales@standex.co.jp

IATF 16949 CERTIFIED · ISO 9001 CERTIFIED · ITAR · NIST · AS9100 CERTIFIED

standexelectronics.com